

May 16, 2022

- CE Declaration of Conformity -

We, Toyotomi Co., Ltd., 5-17, Momozono-cho, Mizuho-ku, Nagoya, Aichi, Japan, declare under our sole responsibility that the following products;

Wall Mounted Split Type Air Conditioners under Toyotomi Brand:

INDOOR UNIT MODEL	OUTDOOR UNIT MODEL
KTN22-24R32	KTG22-24R32

referred to in this declaration conforms with the applicable requirements of the following European directives:

*Standards used to verify the compliance:

LVD: 2014/35/EU

EN 60335-1:2012+A11:2014+A13:2017+A1:2019+A14:2019+A2:2019

EN 60335-2-40:2003+A11:2004+A12:2005+A1:2006+A2:2009+A13:2012+AC:2013

EN 62233:2008

EMC: 2014/30/EU

EN 55014-1:2017

EN 55014-2:2015

EN 61000-3-2:2019

EN 61000-3-3:2013+A1:2019

ErP: 2009/125/EC

Commission Regulation (EU) No 206/2012

Commission Delegated Regulation (EU) No 626/2011

EN 14825:2016

EN 14511-2,3:2013

EN 12102-1:2017

RED: 2014/53/EU

ETSI EN 300 328 V2.2.2 (2019-07)

ETSI EN 301 489-1 V2.2.3 (2019-11)

ETSI EN 301 489-17 V3.2.4 (2020-09)

EN IEC 62311:2020

RoHS Directive: 2011/65/EU (RoHS 2), (EU) 2015/863 (RoHS 3)

TOYOTOMI CO., LTD.


Yoshihiko Hata,
Director